

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-0085:173 Page 1 of 1

**CATEGORY:** Misc. Device/Control Unit Accessories

**LISTEE:** ADT Security Systems, 4128 North Freeway Blvd, Sacramento, CA 95834  
Contact: Ron Dalton (310) 725-2972 Fax (310) 725-2942\*

**DESIGN:** Model **Uni-Com** digital alarm communicator transmitter with Model ABS-8R (optional) enclosure. The unit is used to transmit system status to central station via a standard two-wire telephone switching network. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 21.2-28.2 VDC

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as digital alarm communicator transmitter for use with separately listed compatible fire alarm control units.

**XLF:** 7300-0028:174

\*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager